



表示範囲 2026-01-31 23:44:00 - 2026-03-01 00:16:00

計算範囲 2026-01-31 23:44:00 - 2026-03-01 00:16:00

No.	チャンネル名	記録間隔	データ数	単位	最大値	最小値	平均値
No.1	2F冷P①	15 min.	2681	°C	5.0	4.1	4.5
No.2	2F室温①	15 min.	2690	°C	25.4	22.1	23.8
No.3	2F恒H3①	15 min.	2690	°C	21.2	19.9	20.6
No.4	B1冷B①	15 min.	2690	°C	5.5	4.5	5.0
No.5	B1冷E①	15 min.	2690	°C	5.0	4.3	4.6
No.6	B1冷F①	15 min.	2690	°C	5.2	3.9	4.8
No.7	B1冷I①	15 min.	2690	°C	4.8	4.1	4.5
No.8	B1冷J①	15 min.	2690	°C	5.1	4.1	4.6
No.9	B1冷K①	15 min.	2690	°C	4.9	4.4	4.6
No.10	B1冷N①	15 min.	2690	°C	5.4	4.7	4.9
No.11	B1冷O①	15 min.	2690	°C	4.7	4.0	4.3
No.12	B1冷Q①	15 min.	2690	°C	5.6	4.5	4.9
No.13	B1冷Z①	15 min.	2690	°C	4.4	3.7	4.1
No.14	B1室温①	15 min.	2690	°C	25.2	23.0	24.1
No.15	B1恒H2①	15 min.	2690	°C	21.2	20.5	20.8
No.16	B1恒H4①	15 min.	2690	°C	20.6	20.1	20.3
No.17	B1恒H5①	15 min.	2691	°C	19.9	19.8	19.8
No.18	B1恒H①	15 min.	2690	°C	20.8	20.3	20.4